

Corrective Actions for Schools, Child Care Centres and Large Buildings

Interpreting sample results

The sampling plan is designed to locate lead sources and to help identify where and how to proceed with corrective actions. For example:

- Where both samples from one fixture (A and B) do not contain lead at any level, no further action would be required.
- Where both samples (A and B) contain lead at or below the lead guideline, consider a flushing program.
- Where sample A (the first draw sample) has lead but sample B does not, the source of the lead would likely be from the fixture.
- Where sample B has lead but sample A does not, the source of the lead would likely be from the plumbing behind the fixture.
- Where samples from multiple fixtures have lead, corrective actions should be targeted to the entire facility.
- Where lead concentrations are found in the 1-litre incoming sample, the source is likely a lead service line.

Corrective actions for building owners

Immediate Actions for Reducing Elevated Lead Levels

- Where lead levels are above the national guideline, consider immediate action for reducing lead. This might include:
- Closing plumbing fixtures that exceed the limit (ex: removing handles, posting signs, or bagging the fixture).
- Posting “Do Not Drink” signs on taps that cannot be easily closed.
- Providing an alternate safe drinking water source (ex: bottled water coolers) particularly if the issue is widespread throughout a building.

Maintenance Solutions for Reducing Elevated Lead Levels

- Replace all lead pipes, if present.
- Replace fixtures with new “lead-free” products.
- Add point-of-use filtration devices that are NSF- certified to remove lead, changing filters as often as the manufacturer recommends. See links provided near the end of this factsheet for more information.
- Check for grounding wires attached to water pipes. An electrical current may accelerate the corrosion of lead in piping materials.

Corrective Actions for Schools, Child Care Centres and Large Buildings

- Reconfigure building plumbing to bypass sources of lead contamination. Target the small pipe branches that may have more elbows, joints and therefore more solder.
- Add automatic flushing valves to reduce water stagnation.

Operational Solutions for Reducing Lead Levels

Consider the following steps to reduce lead if levels are below the national guideline but still detectable:

- Implement daily or weekly flushing programs as needed - running all indoor taps and water fountains until the water is clear and cold. The flushing program should be supported with standard operating procedures and initialed logs.
- Schools and child care centres should consider flushing Monday mornings before students arrive each week to remove stagnant water.
- Advise students and staff or residents to run the water until cold before drinking.
- Clean tap aerators regularly.
- Use only cold clear water for food and beverage preparation. Hot water will dissolve lead more quickly than cold water and is likely to contain increased levels of lead or other contaminants.

Corrective actions for tenants and renters

It is recommended that tenants and renters share test results and renters share test results with their building owner or maintenance committee. Where lead levels are above the national guideline, tenants and renters should consider the following options for reducing lead exposure:

- Use an alternate safe drinking water source (ex: bottled water)

- Use a pitcher-type filter, or point-of-use filter that attaches to the kitchen tap. Filters must be NSF-certified to remove lead, and must be changed as often as the manufacturer recommends. Filters are available at many hardware or grocery stores. See links provided near the end of this factsheet for more information.
- Clean tap aerators regularly.
- Using only cold clear water for food and beverage preparation.

Communication plan

In addition to testing for lead and taking corrective actions, consider developing a communication plan to advise parents or residents and make the results available to them. If increased lead levels are identified, communicate on actions taken to correct the problems found.

Manitoba Health, Seniors and Active Living and the Regional Health Authority can assist with health risk communication to the public. An example of a communication notice is found here: [manitoba.ca/sd/water/drinking_water/lead/public_communication_ex.pdf](https://www.manitoba.ca/sd/water/drinking_water/lead/public_communication_ex.pdf)

For additional information, see the fact sheet *Lead in Drinking Water: Information for Manitoba Schools, Child Care Centres and Large Buildings*

Water testing results October-December 2019

| Parameter | Client Sample ID | Results | X | Immediate action | Plan | Re-sample Date | Re-test results | Further Action | 2nd re-test Results |
|-----------------------------|-----------------------------|----------|---|------------------|------------------------------|----------------|-----------------|----------------|---------------------|
| Total Metals (Water) | | | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 1A | 0.131 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 1A | 0.00107 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 1B | 0.130 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 1B | 0.00103 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 2A | 0.182 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 2A | 0.00199 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 2B | 0.168 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 2B | 0.00168 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 3A | 0.170 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 3A | 0.000997 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 3B | 0.160 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 3B | 0.000647 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 4A | 0.110 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 4A | 0.000443 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 4B | 0.108 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 4B | 0.000489 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 5A | 0.116 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 5A | 0.000505 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 5B | 0.102 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 5B | 0.000325 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 6A | 0.621 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 6A | 0.0285 | x | Shut off water | Remove (in room off library) | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 6B | 0.682 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 6B | 0.0295 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 7A | 0.0807 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 7A | 0.000287 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 7B | 0.0744 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 7B | 0.000142 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 8A | 0.0857 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 8A | 0.000275 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 8B | 0.0769 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 8B | 0.000260 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 9A | 0.165 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 9A | 0.00109 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 10A | 0.101 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 10A | 0.000725 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 10B | 0.0908 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 10B | 0.000342 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 11A | 0.368 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 11A | 0.000445 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 11B | 0.443 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 11B | 0.000351 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 12A | 0.228 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 12A | 0.000892 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 12B | 0.288 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 12B | 0.00115 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 13A | 0.138 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 13A | 0.000456 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 13B | 0.195 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 13B | 0.00200 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 14A | 0.191 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 14A | 0.00148 | | N/A | | | | | |
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 14B | 0.180 | | N/A | | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 14B | 0.000718 | | N/A | | | | | |

| | | | | | | | | |
|-------------------|---------------------------------------|----------|---|----------------|---|--|--|--|
| Copper (Cu)-Total | 140 - BUCHANAN SCHOOL - 15 - SOURCE | 0.0685 | | N/A | | | | |
| Lead (Pb)-Total | 140 - BUCHANAN SCHOOL - 15 - SOURCE | 0.00241 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 1A | 0.162 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 1A | 0.000258 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 1B | 0.171 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 1B | 0.000164 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 2A | 0.244 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 2A | 0.000680 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 2B | 0.274 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 2B | 0.000475 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 3A | 0.526 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 3A | 0.000811 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 3B | 0.614 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 3B | 0.00123 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 4A | 0.223 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 4A | 0.000452 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 4B | 0.220 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 4B | 0.000588 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 5A | 0.148 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 5A | 0.000771 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 6A | 0.163 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 6A | 0.000365 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 6B | 0.157 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 6B | 0.000368 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 7A | 0.124 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 7A | 0.000164 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 7B | 0.124 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 7B | 0.000134 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 8A | 0.116 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 8A | 0.000165 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 8B | 0.126 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 8B | 0.000155 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 9A | 0.246 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 9A | 0.00278 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 9B | 0.299 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 9B | 0.00334 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 10A | 0.276 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 10A | 0.00249 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 10B | 0.439 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 10B | 0.00505 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 11A | 0.255 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 11A | 0.00228 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 11B | 0.405 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 11B | 0.00246 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 12A | 0.297 | | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 12A | 0.00577 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 12B | 0.271 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 12B | 0.00321 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 13A | 0.322 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 13A | 0.00308 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 13B | 0.359 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 13B | 0.00350 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 14A | 0.212 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 14A | 0.000470 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 14B | 0.217 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 14B | 0.000430 | | N/A | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 15A | 0.269 | | N/A | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 15A | 0.0120 | x | Shut off water | Remove (in room off library) | | | |

| | | | | | | | | |
|-------------------|---------------------------------------|----------|-----|--|--|--|--|--|
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 15B | 0.551 | N/A | | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 15B | 0.00608 | N/A | | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 16A | 0.173 | N/A | | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 16A | 0.00297 | N/A | | | | | |
| Copper (Cu)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 16B | 0.168 | N/A | | | | | |
| Lead (Pb)-Total | 330 - GOLDEN GATE MIDDLE SCHOOL - 16B | 0.00200 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 1A | 0.718 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 1A | 0.000791 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 1B | 0.633 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 1B | 0.000514 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 2A | 0.298 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 2A | 0.00267 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 2B | 0.599 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 2B | 0.00195 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 3A | 0.263 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 3A | 0.000143 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 3B | 0.264 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 3B | 0.000118 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 4A | 0.268 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 4A | 0.000298 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 4B | 0.308 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 4B | 0.000198 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 5A | 0.435 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 5A | 0.000219 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 5B | 0.523 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 5B | 0.000187 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 6A | 0.586 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 6A | 0.00124 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 6B | 0.587 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 6B | 0.000902 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 7A | 0.525 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 7A | 0.000994 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 7B | 0.573 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 7B | 0.00102 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 8A - SOURCE | 0.239 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 8A - SOURCE | 0.000166 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 9A | 0.393 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 9A | 0.00212 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 9B | 0.384 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 9B | 0.00223 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 10A | 0.344 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 10A | 0.00184 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 10B | 0.312 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 10B | 0.00133 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 11A | 0.562 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 11A | 0.00197 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 11B | 0.631 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 11B | 0.00365 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 12A | 0.506 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 12A | 0.00330 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 12B | 0.589 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 12B | 0.00291 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 13A | 0.516 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 13A | 0.00119 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 13B | 0.675 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 13B | 0.000690 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 14A | 0.519 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 14A | 0.00275 | N/A | | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 14B | 0.537 | N/A | | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 14B | 0.00204 | N/A | | | | | |

| | | | | | | | | |
|-------------------|---------------------------|----------|---|----------------|---|--|--|--|
| Copper (Cu)-Total | PHOENIX SCHOOL - 15A | 0.499 | | N/A | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 15A | 0.00135 | | N/A | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 15B | 0.538 | | N/A | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 15B | 0.00172 | | N/A | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 16A | 0.631 | | N/A | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 16A | 0.00165 | | N/A | | | | |
| Copper (Cu)-Total | PHOENIX SCHOOL - 16B | 0.650 | | N/A | | | | |
| Lead (Pb)-Total | PHOENIX SCHOOL - 16B | 0.00163 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 1 | 0.406 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 1 | 0.00775 | x | Shut off water | Remove | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 1 | 0.420 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 1 | 0.00943 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 2 | 0.420 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 2 | 0.0349 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 2 | 0.865 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 2 | 0.00544 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 3 | 0.287 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 3 | 0.00212 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 3 | 0.365 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 3 | 0.00281 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 4 | 0.195 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 4 | 0.000878 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 4 | 0.280 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 4 | 0.00615 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 5 | 0.521 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 5 | 0.00231 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 5 | 0.581 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 5 | 0.00174 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 6 | 0.488 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 6 | 0.00213 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 6 | 0.560 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 6 | 0.00164 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 7 | 0.274 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 7 | 0.00230 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 7 | 0.589 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 7 | 0.0087 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 8 | 0.168 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 8 | 0.00262 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 8 | 0.354 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 8 | 0.00479 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 9 | 0.275 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 9 | 0.00283 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 9 | 0.411 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 9 | 0.00546 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 10 | 0.381 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 10 | 0.00311 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 10 | 0.354 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 10 | 0.00238 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 11 | 0.281 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 11 | 0.00220 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 11 | 0.270 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 11 | 0.00227 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 12 | 0.151 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 12 | 0.000715 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 12 | 0.143 | | N/A | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 12 | 0.000790 | | N/A | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 13 | 0.165 | | N/A | | | | |

| | | | | | | | | | |
|-------------------|---|-----------|-----|--|--|--|--|--|--|
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 13 | 0.000692 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 13 | 0.138 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 13 | 0.000565 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 14 | 0.337 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 14 | 0.00204 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 14 | 0.281 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 14 | 0.00310 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 15 | 0.0976 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 15 | 0.000305 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 15 | 0.100 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 15 | 0.000632 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 16 | 0.198 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 16 | 0.000222 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 16 | 0.141 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 16 | 0.000225 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 17 | 0.00380 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 17 | <0.000050 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 17 | 0.00187 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 17 | <0.000050 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 18 | 0.310 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 18 | 0.000689 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 18 | 0.312 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 18 | 0.000720 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 19 | 0.291 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 19 | 0.000804 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 19 | 0.296 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 19 | 0.000800 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 20 | 0.243 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 20 | 0.00176 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 20 | 0.239 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 20 | 0.00106 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 21 | 0.221 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 21 | 0.000280 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 21 | 0.241 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 21 | 0.000349 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 22 | 0.228 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 22 | 0.000388 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 22 | 0.244 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 22 | 0.000301 | N/A | | | | | | |
| Copper (Cu)-Total | HEDGES MIDDLE SCHOOL - 23 - SOURCE | 0.0187 | N/A | | | | | | |
| Lead (Pb)-Total | HEDGES MIDDLE SCHOOL - 23 - SOURCE | 0.000134 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 1 - SOURCE | 0.779 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 1 - SOURCE | 0.000719 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 2A | 0.192 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 2A | 0.000740 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 2B | 0.185 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 2B | 0.000681 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 3A | 0.0720 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 3A | 0.000325 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 3B | 0.0733 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 3B | 0.000367 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 4A | 0.118 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 4A | 0.000789 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 4B | 0.0765 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 4B | 0.000422 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 5A | 0.203 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 5A | 0.000125 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 5B | 0.194 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 5B | 0.000163 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 6A | 0.197 | N/A | | | | | | |

| | | | | | | | | | |
|-------------------|------------------------------------|----------|-----|--|--|--|--|--|--|
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 6A | 0.000151 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 6B | 0.181 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 6B | 0.000132 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 7A | 0.540 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 7A | 0.00133 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 7B | 0.331 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 7B | 0.00166 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 8A | 0.194 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 8A | 0.00147 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 8B | 0.155 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 8B | 0.000883 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 9A | 0.299 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 9A | 0.000806 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 9B | 0.294 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 9B | 0.000857 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 10A | 0.273 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 10A | 0.00116 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 10B | 0.292 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 10B | 0.00105 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 11A | 0.161 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 11A | 0.000457 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 11B | 0.148 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 11B | 0.000451 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 12A | 0.161 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 12A | 0.000480 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 12B | 0.140 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 12B | 0.000390 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 13A | 0.194 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 13A | 0.00112 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 13B | 0.193 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 13B | 0.000781 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 14A | 0.297 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 14A | 0.00187 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 14B | 0.304 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 14B | 0.00147 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 15A | 0.198 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 15A | 0.000974 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 15B | 0.178 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 15B | 0.00125 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 16A | 0.177 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 16A | 0.000684 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 16B | 0.180 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 16B | 0.000989 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 17A | 0.232 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 17A | 0.00153 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 17B | 0.269 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 17B | 0.00119 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 18A | 0.119 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 18A | 0.000366 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 18B | 0.0534 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 18B | 0.000118 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 19A | 0.303 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 19A | 0.00148 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 19B | 0.282 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 19B | 0.00130 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 20A | 0.131 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 20A | 0.000371 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 20B | 0.127 | N/A | | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 20B | 0.000383 | N/A | | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 21A | 0.128 | N/A | | | | | | |

| | | | | | | | | |
|-------------------|--|----------|-----|---------------------|---|--|--|--|
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 21A | 0.000391 | N/A | | | | | |
| Copper (Cu)-Total | 190 - ROBERT BROWNING SCHOOL - 21B | 0.126 | N/A | | | | | |
| Lead (Pb)-Total | 190 - ROBERT BROWNING SCHOOL - 21B | 0.000673 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 1A | 0.196 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 1A | 0.000738 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 1B | 0.211 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 1B | 0.000647 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 2A | 0.555 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 2A | 0.00702 | x | "Do not drink" sign | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 2B | 0.518 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 2B | 0.00773 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 3A | 0.0789 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 3A | 0.000397 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 3B | 0.0835 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 3B | 0.000268 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 4A | 0.0767 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 4A | 0.000364 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 4B | 0.0753 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 4B | 0.000427 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 5 - SOURCE | 0.148 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 5 - SOURCE | 0.00445 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 6A | 0.401 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 6A | 0.000839 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 6B | 0.342 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 6B | 0.000873 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 7A | 0.305 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 7A | 0.000237 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 7B | 0.331 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 7B | 0.000180 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 8A | 0.352 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 8A | 0.000208 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 8B | 0.359 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 8B | 0.000229 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 9A | 0.147 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 9A | 0.000310 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 9B | 0.0978 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 9B | 0.000200 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 10A | 0.151 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 10A | 0.000285 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 10B | 0.171 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 10B | 0.000678 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 11A | 0.305 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 11A | 0.000776 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 11B | 0.313 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 11B | 0.00108 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 12 - SOURCE | 0.150 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 12 - SOURCE | 0.000423 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 13A | 0.186 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 13A | 0.00248 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 13B | 0.214 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 13B | 0.000917 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 14A | 0.334 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 14A | 0.000139 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 14B | 0.224 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 14B | 0.000065 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 15A | 0.172 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 15A | 0.000403 | N/A | | | | | |
| Copper (Cu)-Total | 130 - ASSINIBOINE SCHOOL - 15B | 0.190 | N/A | | | | | |
| Lead (Pb)-Total | 130 - ASSINIBOINE SCHOOL - 15B | 0.000119 | N/A | | | | | |

| | | | | | | | | | |
|-------------------|--------------------------------------|----------|---|--|---|--|--|--|--|
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 1A | 0.393 | x | No action required, Not for drinking water | Sink in Kindergarten used for tempura paint etc. Teacher will ensure it is not used for drinking. "Do not drink" sign is posted | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 1A | 0.0188 | x | No action required, Not for drinking water | Sink in Kindergarten used for tempura paint etc. Teacher will ensure it is not used for drinking. "Do not drink" sign is posted | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 2A | 0.187 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 2A | 0.00109 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 2B | 0.146 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 2B | 0.000778 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 3A | 0.140 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 3A | 0.00139 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 3B | 0.121 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 3B | 0.000864 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 4A | 0.204 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 4A | 0.000825 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 4B | 0.205 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 4B | 0.000847 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 5A | 0.235 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 5A | 0.000883 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 5B | 0.242 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 5B | 0.000539 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 6 - SOURCE | 0.0176 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 6 - SOURCE | 0.000252 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 7A | 0.145 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 7A | 0.000471 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 7B | 0.138 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 7B | 0.000422 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 8A | 0.127 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 8A | 0.000664 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 8B | 0.124 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 8B | 0.000297 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 9A | 0.446 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 9A | 0.00114 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 9B | 0.473 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 9B | 0.000871 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 10A | 0.446 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 10A | 0.000976 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 10B | 0.466 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 10B | 0.00140 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 11A | 0.275 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 11A | 0.000358 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 11B | 0.265 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 11B | 0.000451 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 12A | 0.388 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 12A | 0.00219 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 12B | 0.328 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 12B | 0.00298 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 13A | 0.139 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 13A | 0.000453 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 13B | 0.115 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 13B | 0.000454 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 14A | 0.106 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 14A | 0.000638 | | N/A | | | | | |
| Copper (Cu)-Total | 115 - ATHLONE SCHOOL - 14B | 0.0904 | | N/A | | | | | |
| Lead (Pb)-Total | 115 - ATHLONE SCHOOL - 14B | 0.000368 | | N/A | | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 1A - SOURCE | 0.0587 | | N/A | | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 1A - SOURCE | 0.000363 | | N/A | | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 2A | 0.0883 | | N/A | | | | | |

| | | | | | | | | |
|-------------------|------------------------------|----------|---|----------------|---|--|--|--|
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 2A | 0.00171 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 2B | 0.0979 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 2B | 0.000248 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 3A | 0.438 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 3A | 0.00505 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 3B | 0.484 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 3B | 0.00740 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 4A | 0.144 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 4A | 0.00155 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 4B | 0.111 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 4B | 0.000813 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 5A | 0.156 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 5A | 0.00155 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 5B | 0.130 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 5B | 0.000999 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 6A | 0.132 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 6A | 0.00103 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 6B | 0.123 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 6B | 0.00100 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 7A | 0.370 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 7A | 0.0159 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 7B | 0.628 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 7B | 0.00738 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 8A | 0.0989 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 8A | 0.000561 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 8B | 0.114 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 8B | 0.000495 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 9A | 0.378 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 9A | 0.00109 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 9B | 0.483 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 9B | 0.00207 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 10A | 0.123 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 10A | 0.000185 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 10B | 0.118 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 10B | 0.000181 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 11A | 0.135 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 11A | 0.000547 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 11B | 0.130 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 11B | 0.000499 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 12A | 0.322 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 12A | 0.00425 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 12B | 0.328 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 12B | 0.00345 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 13A | 0.110 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 13A | 0.000709 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 13B | 0.0981 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 13B | 0.000619 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 14A | 0.109 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 14A | 0.000592 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 14B | 0.0853 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 14B | 0.000548 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 15A | 0.226 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 15A | 0.000774 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 15B | 0.224 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 15B | 0.00991 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 16A | 0.222 | | N/A | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 16A | 0.00105 | | N/A | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 16B | 0.185 | | N/A | | | | |

| | | | | | | | | |
|-------------------|--------------------------------|----------|-----|----------------|---|--|--|--|
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 16B | 0.000483 | N/A | | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 17A | 0.375 | N/A | | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 17A | 0.000442 | N/A | | | | | |
| Copper (Cu)-Total | 195 - STEVENSON SCHOOL - 17B | 0.373 | N/A | | | | | |
| Lead (Pb)-Total | 195 - STEVENSON SCHOOL - 17B | 0.000360 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 1A | 0.202 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 1A | 0.000615 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 1B | 0.195 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 1B | 0.000536 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 2A | 0.0980 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 2A | 0.000594 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 2B | 0.0809 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 2B | 0.000324 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 3A | 0.150 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 3A | 0.000248 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 3B | 0.148 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 3B | 0.000200 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 4A | 0.0986 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 4A | 0.000750 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 4B | 0.0697 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 4B | 0.000234 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 5A | 0.179 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 5A | 0.00126 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 5B | 0.177 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 5B | 0.000597 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 6A | 0.231 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 6A | 0.00494 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 6B | 0.219 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 6B | 0.00434 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 7A | 0.225 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 7A | 0.00420 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 7B | 0.193 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 7B | 0.00648 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 8A | 0.226 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 8A | 0.00102 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 8B | 0.228 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 8B | 0.00131 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 9A | 0.604 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 9A | 0.0316 | N/A | | | | | |
| Copper (Cu)-Total | 350 - SANSOME SCHOOL - 9B | 0.689 | N/A | | | | | |
| Lead (Pb)-Total | 350 - SANSOME SCHOOL - 9B | 0.0182 | x | Shut off water | Remove basement fountain (old) as it is seldom used | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 1A | 0.146 | N/A | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 1A | 0.000288 | N/A | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 1B | 0.139 | N/A | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 1B | 0.000191 | N/A | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 2A | 0.140 | N/A | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 2A | 0.000279 | N/A | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 2B | 0.116 | N/A | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 2B | 0.000094 | N/A | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 3A | 0.127 | N/A | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 3A | 0.000157 | N/A | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 3B | 0.128 | N/A | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 3B | 0.000160 | N/A | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 4A | 0.176 | N/A | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 4A | 0.000661 | N/A | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 4B | 0.169 | N/A | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 4B | 0.000583 | N/A | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 5A | 0.176 | N/A | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 5A | 0.000663 | N/A | | | | | |

| | | | | | | | | | |
|-------------------|--|-----------|-----|--|--|--|--|--|--|
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 5B | 0.151 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 5B | 0.000582 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 6 - SOURCE | 0.829 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 6 - SOURCE | 0.00383 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 7A | 0.507 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 7A | 0.000451 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 7B | 0.399 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 7B | 0.000174 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 8A | 0.196 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 8A | 0.00116 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 8B | 0.194 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 8B | 0.00153 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 9A | 0.156 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 9A | 0.000125 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 9B | 0.146 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 9B | 0.000224 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 10A | 0.0994 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 10A | 0.000526 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 10B | 0.149 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 10B | 0.000350 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 11A | 0.0607 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 11A | 0.000280 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 11B | 0.0629 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 11B | 0.000231 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 13A | 0.330 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 13A | 0.00205 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 13B | 0.447 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 13B | 0.00106 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 14A | 0.359 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 14A | <0.000050 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 14B | 0.414 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 14B | 0.000053 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 15A | 0.0775 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 15A | 0.000061 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 15B | 0.0853 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 15B | <0.000050 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 16A | 0.0862 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 16A | 0.000062 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 16B | 0.0909 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 16B | <0.000050 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 17A | 0.258 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 17A | 0.00163 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 17B | 0.325 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 17B | 0.00794 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 18A | 0.0611 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 18A | <0.000050 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 18B | 0.0504 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 18B | 0.000072 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 19A | 0.485 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 19A | 0.00648 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 19B | 0.871 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 19B | 0.00432 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 20A | 0.455 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 20A | 0.00251 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 20B | 0.702 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 20B | 0.00152 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 21A | 0.117 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 21A | 0.000069 | N/A | | | | | | |
| Copper (Cu)-Total | 200 - STRATHMILLAN SCHOOL - 21B | 0.127 | N/A | | | | | | |
| Lead (Pb)-Total | 200 - STRATHMILLAN SCHOOL - 21B | <0.000050 | N/A | | | | | | |

| | | | | | | | | |
|-------------------|---|----------|-----|--|--|--|--|--|
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 1A | 0.357 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 1A | 0.00122 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 1B | 0.386 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 1B | 0.00115 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 2A | 0.122 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 2A | 0.000311 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 2B | 0.110 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 2B | 0.000234 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 3A | 0.120 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 3A | 0.000262 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 3B | 0.128 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 3B | 0.000166 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 4A | 0.140 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 4A | 0.000248 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 4B | 0.131 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 4B | 0.000255 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 5A | 0.116 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 5A | 0.00129 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 5B | 0.109 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 5B | 0.000613 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 6 - SOURCE | 0.299 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 6 - SOURCE | 0.00272 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 7A | 0.247 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 7A | 0.000853 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 7B | 0.242 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 7B | 0.000889 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 8A | 0.124 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 8A | 0.000106 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 8B | 0.107 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 8B | 0.000076 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 9 - CARTAKER ROOM | 0.0604 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 9 - CARTAKER ROOM | 0.000100 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 10A | 0.0900 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 10A | 0.000288 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 10B | 0.0823 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 10B | 0.000278 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 11A | 0.353 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 11A | 0.000704 | N/A | | | | | |
| Copper (Cu)-Total | 315 - BROOKLANDS SCHOOL - 11B | 0.297 | N/A | | | | | |
| Lead (Pb)-Total | 315 - BROOKLANDS SCHOOL - 11B | 0.000374 | N/A | | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 1A | 0.336 | N/A | | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 1A | 0.00194 | N/A | | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 1B | 0.411 | N/A | | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 1B | 0.00127 | N/A | | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 2A | 0.312 | N/A | | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 2A | 0.00101 | N/A | | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 2B | 0.473 | N/A | | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 2B | 0.00130 | N/A | | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 3A | 0.0625 | N/A | | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 3A | 0.000223 | N/A | | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 3B | 0.0587 | N/A | | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 3B | 0.000211 | N/A | | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 4A | 0.0614 | N/A | | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 4A | 0.000230 | N/A | | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 4B | 0.0580 | N/A | | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 4B | 0.000305 | N/A | | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 5A | 0.0895 | N/A | | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 5A | 0.000669 | N/A | | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 5B | 0.0798 | N/A | | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 5B | 0.000467 | N/A | | | | | |

| | | | | | | | |
|-------------------|---|----------|------------------|---|--|--|--|
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 6A | 0.0682 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 6A | 0.000324 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 6B | 0.0565 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 6B | 0.000453 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 7A | 0.0594 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 7A | 0.000377 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 7B | 0.0542 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 7B | 0.000365 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 8A | 0.0985 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 8A | 0.000547 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 8B | 0.0511 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 8B | 0.000334 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 9A | 0.221 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 9A | 0.00610 | x Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 9B | 0.512 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 9B | 0.00387 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 10A | 0.257 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 10A | 0.000444 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 10B | 0.298 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 10B | 0.000849 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 11A | 0.306 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 11A | 0.00110 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 11B | 0.359 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 11B | 0.00108 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 12A | 0.289 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 12A | 0.00225 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 12B | 0.381 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 12B | 0.00392 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 13A | 0.350 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 13A | 0.00271 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 13B | 0.397 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 13B | 0.00256 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 14A | 0.256 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 14A | 0.000959 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 14B | 0.247 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 14B | 0.000927 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 15A | 0.0967 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 15A | 0.000452 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 15B | 0.0680 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 15B | 0.000210 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 16A | 0.0858 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 16A | 0.000189 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 16B | 0.0740 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 16B | 0.000173 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 17A | 0.124 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 17A | 0.000152 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 17B | 0.121 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 17B | 0.000162 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 18A | 0.0411 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 18A | 0.000080 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 18B | 0.0330 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 18B | 0.000123 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 19A | 0.0365 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 19A | 0.000085 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 19B | 0.0339 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 19B | 0.000083 | N/A | | | | |
| Copper (Cu)-Total | 340 - LINCOLN MIDDLE SCHOOL - 20 - SOURCE | 0.0382 | N/A | | | | |
| Lead (Pb)-Total | 340 - LINCOLN MIDDLE SCHOOL - 20 - SOURCE | 0.000080 | N/A | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 1A | 0.295 | N/A | | | | |

| | | | | | | | | | |
|-------------------|------------------------|----------|---|----------------|---|-----------|---------|---|--|
| Lead (Pb)-Total | ECOLE NESS - 345 - 1A | 0.00140 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 1B | 0.291 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 1B | 0.00500 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 2A | 0.268 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 2A | 0.000706 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 2B | 0.256 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 2B | 0.000633 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 3A | 0.254 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 3A | 0.000748 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 3B | 0.242 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 3B | 0.000445 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 4A | 0.171 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 4A | 0.000450 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 4B | 0.160 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 4B | 0.00126 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 5A | 0.142 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 5A | 0.000448 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 5B | 0.156 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 5B | 0.000412 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 6A | 0.144 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 6A | 0.000487 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 6B | 0.122 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 6B | 0.000300 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 7A | 0.131 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 7A | 0.000350 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 7B | 0.118 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 7B | 0.000271 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 8A | 0.228 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 8A | 0.000582 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 8B | 0.225 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 8B | 0.000457 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 9A | 0.232 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 9A | 0.000469 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 9B | 0.223 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 9B | 0.000369 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 10A | 0.182 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 10A | 0.000573 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 10B | 0.155 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 10B | 0.000407 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 11A | 0.157 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 11A | 0.000453 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 11B | 0.172 | | N/A | | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 11B | 0.000546 | | N/A | | | | | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 12A | 0.810 | | N/A | | | | 0.407 | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 12A | 0.109 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | 11-Dec-19 | 0.00240 | within guideline | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 12B | 3.10 | | Shut off water | | | 0.519 | Replace faucets to lower further. Note: soft metal connection between pipe and faucet is suspect to contain lead so it was also removed | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 12B | 0.217 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | 11-Dec-19 | 0.00575 | Replace faucets to lower further. Note: soft metal connection between pipe and faucet is suspect to contain lead so it was also removed | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 13A | 0.854 | | Shut off water | | | 0.346 | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 13A | 0.0234 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | 11-Dec-19 | 0.00306 | within guideline | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 13B | 0.947 | | Shut off water | | | 0.516 | | |

| | | | | | | | | |
|-------------------|--------------------------------|----------|---|----------------|--|-----------|---------|---|
| Lead (Pb)-Total | ECOLE NESS - 345 - 13B | 0.0133 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | 11-Dec-19 | 0.00537 | Replace faucets to lower further. Note: soft metal connection between pipe and faucet is suspect to contain lead so it was also removed |
| Copper (Cu)-Total | ECOLE NESS - 345 - 14A | 0.288 | | Shut off water | | | 0.177 | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 14A | 0.00960 | | Shut off water | | | 0.00446 | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 14B | 0.611 | | Shut off water | | | 0.544 | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 14B | 0.0138 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | 11-Dec-19 | 0.0130 | Replace faucets to lower further. Note: soft metal connection between pipe and faucet is suspect to contain lead so it was also removed |
| Copper (Cu)-Total | ECOLE NESS - 345 - 15A | 1.93 | | Shut off water | | | 0.377 | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 15A | 0.0205 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | 11-Dec-19 | 0.00222 | within guideline |
| Copper (Cu)-Total | ECOLE NESS - 345 - 15B | 3.64 | | Shut off water | | | 0.500 | within guideline |
| Lead (Pb)-Total | ECOLE NESS - 345 - 15B | 0.0215 | | Shut off water | | | 0.00187 | within guideline |
| Copper (Cu)-Total | ECOLE NESS - 345 - 16A | 5.01 | | Shut off water | | | 0.249 | Flush and re-test |
| Lead (Pb)-Total | ECOLE NESS - 345 - 16A | 0.177 | | Shut off water | | | 0.00179 | within guideline |
| Copper (Cu)-Total | ECOLE NESS - 345 - 16B | 2.57 | | Shut off water | | | 0.551 | within guideline |
| Lead (Pb)-Total | ECOLE NESS - 345 - 16B | 0.0749 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. Replace faucets to lower further | 11-Dec-19 | 0.00380 | within guideline |
| Copper (Cu)-Total | ECOLE NESS - 345 - 17A | 0.506 | | Shut off water | | | 0.249 | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 17A | 0.00937 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. Replace faucets to lower further | 11-Dec-19 | 0.00126 | within guideline |
| Copper (Cu)-Total | ECOLE NESS - 345 - 17B | 0.916 | | Shut off water | | | 0.500 | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 17B | 0.00423 | | Shut off water | | | 0.00404 | |
| Copper (Cu)-Total | ECOLE NESS - 345 - 18A | 1.12 | | Shut off water | | | 0.449 | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 18A | 0.0782 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | 11-Dec-19 | 0.0171 | Replace faucets to lower further. Note: soft metal connection between pipe and faucet is suspect to contain lead so it was also removed |
| Copper (Cu)-Total | ECOLE NESS - 345 - 18B | 0.798 | | Shut off water | | | 0.656 | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 18B | 0.0298 | | Shut off water | | | 0.0159 | Replace faucets to lower further |
| Copper (Cu)-Total | ECOLE NESS - 345 - 19A SOURCE | 0.219 | | N/A | | | | |
| Lead (Pb)-Total | ECOLE NESS - 345 - 19A SOURCE | 0.00229 | | N/A | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 1A | 0.170 | | N/A | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 1A | 0.000754 | | N/A | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 1B | 0.154 | | N/A | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 1B | 0.000677 | | N/A | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 2A | 0.0883 | | N/A | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 2A | 0.000214 | | N/A | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 2B | 0.0876 | | N/A | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 2B | 0.000234 | | N/A | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 3A | 0.114 | | N/A | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 3A | 0.00167 | | N/A | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 3B | 0.111 | | N/A | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 3B | 0.00153 | | N/A | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 4A | 0.107 | | N/A | | | | |
| | | | | N/A | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 4A | 0.0404 | x | Shut off water | Check for galvanized nipples, flush, and re-test | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 4B | 0.112 | | N/A | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 4B | 0.00648 | | N/A | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 5A | 0.267 | | N/A | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 5A | 0.00207 | | N/A | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 5B | 0.269 | | N/A | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 5B | 0.00117 | | N/A | | | | |

| | | | | | | | | |
|-------------------|--|----------|--|--|--|--|--|--|
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 6A | 0.207 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 6A | 0.000973 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 6B | 0.199 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 6B | 0.00103 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 7A | 0.218 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 7A | 0.000658 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 7B | 0.217 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 7B | 0.00358 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 8A | 0.223 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 8A | 0.000755 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 8B | 0.503 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 8B | 0.000942 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 9A | 0.246 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 9A | 0.00196 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 9B | 0.260 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 9B | 0.00187 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 10A | 0.207 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 10A | 0.00126 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 10B | 0.229 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 10B | 0.00350 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 11A | 0.197 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 11A | 0.00229 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 11B | 0.287 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 11B | 0.00386 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 12A | 0.238 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 12A | 0.00126 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 12B | 0.218 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 12B | 0.00191 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 13A | 0.231 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 13A | 0.00138 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 13B | 0.240 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 13B | 0.00115 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 14A | 0.215 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 14A | 0.00104 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 14B | 0.244 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 14B | 0.00134 | N/A | | | | | |
| Copper (Cu)-Total | BRUCE MIDDLE SCHOOL - 320 - 15A SOURCE | 0.227 | N/A | | | | | |
| Lead (Pb)-Total | BRUCE MIDDLE SCHOOL - 320 - 15A SOURCE | 0.0214 | No action required, Not for drinking water | | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 1A | 0.213 | N/A | | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 1A | 0.000481 | N/A | | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 1B | 0.204 | N/A | | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 1B | 0.000393 | N/A | | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 2A | 0.184 | N/A | | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 2A | 0.000402 | N/A | | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 2B | 0.156 | N/A | | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 2B | 0.000220 | N/A | | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 3A | 0.184 | N/A | | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 3A | 0.000356 | N/A | | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 3B | 0.145 | N/A | | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 3B | 0.000236 | N/A | | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 4A | 0.178 | N/A | | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 4A | 0.000120 | N/A | | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 4B | 0.158 | N/A | | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 4B | 0.000096 | N/A | | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 5A | 0.359 | N/A | | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 5A | 0.000112 | N/A | | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 5B | 0.329 | N/A | | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 5B | 0.000107 | N/A | | | | | |

| | | | | | | | | |
|-------------------|--|----------|---|--|---|--|--|--|
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 6A | 0.502 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 6A | 0.000081 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 6B | 0.498 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 6B | 0.000074 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 7A SOURCE | 0.0889 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 7A SOURCE | 0.000269 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 8A | 0.115 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 8A | 0.000115 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 8B | 0.118 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 8B | 0.000122 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 9A | 0.130 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 9A | 0.000129 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 9B | 0.124 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 9B | 0.000118 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 10A | 0.127 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 10A | 0.000385 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 10B | 0.111 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 10B | 0.000200 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 11A | 0.387 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 11A | 0.00168 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 11B | 0.897 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 11B | 0.00800 | x | Shut off water | Remove galvanized connection, flush, and re-test | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 12A | 0.187 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 12A | 0.000125 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 12B | 0.203 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 12B | 0.000147 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 13A | 0.158 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 13A | 0.000661 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 13B | 0.167 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 13B | 0.000854 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 14A | 0.139 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 14A | 0.000140 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 14B | 0.166 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 14B | 0.000215 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 15A | 0.210 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 15A | 0.000491 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 15B | 0.195 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 15B | 0.000490 | | N/A | | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 16A (daycare) | 2.32 | x | Shut off water | Flush and re-test | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 16A (daycare) | 0.00975 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | LAKEWOOD SCHOOL - 175 - 16B (daycare) | 3.81 | | N/A | | | | |
| Lead (Pb)-Total | LAKEWOOD SCHOOL - 175 - 16B (daycare) | 0.0151 | | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 1A | 0.308 | | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 1A | 0.00101 | | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 1B | 0.306 | | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 1B | 0.000600 | | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 2A | 0.388 | | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 2A | 0.00306 | | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 2B | 0.458 | | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 2B | 0.00371 | | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 3A SOURCE | 11.2 | | No action required, Not for drinking water | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 3A SOURCE | 1.20 | | No action required, Not for drinking water | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 4A | 0.393 | | N/A | | | | |

| | | | | | | | |
|-------------------|---|-----------|--|--|--|--|--|
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 4A | <0.000050 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 4B | 0.380 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 4B | <0.000050 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 5A | 0.277 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 5A | <0.000050 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 5B | 0.283 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 5B | <0.000050 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 6A | 0.393 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 6A | 0.000527 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 6B | 0.446 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 6B | 0.000055 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 7A | 0.270 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 7A | 0.000303 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 7B | 0.383 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 7B | 0.000090 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 8A | 0.422 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 8A | 0.00207 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 8B | 0.401 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 8B | 0.00223 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 9A | 0.228 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 9A | 0.000109 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 9B | 0.237 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 9B | 0.000116 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 10A | 0.101 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 10A | 0.000085 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 10B | 0.0980 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 10B | 0.000072 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 11A | 0.146 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 11A | 0.000144 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 11B | 0.105 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 11B | 0.000088 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 12A | 0.0833 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 12A | 0.000055 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 12B | 0.0960 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 12B | 0.000052 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 13A | 0.119 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 13A | 0.000082 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 13B | 0.139 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 13B | 0.000092 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 14A | 0.360 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 14A | 0.000267 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 14B | 0.458 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 14B | 0.000226 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 15A | 0.119 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 15A | 0.000257 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 15B | 0.110 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 15B | 0.000349 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 16A | 0.0930 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 16A | 0.000273 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 16B | 0.0903 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 16B | 0.000289 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 17A SOURCE | 1.16 | No action required, Not for drinking water | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 17A SOURCE | 0.0984 | No action required, Not for drinking water | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 18A | 0.285 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 18A | 0.000552 | N/A | | | | |

| | | | | | | | | |
|-------------------|----------------------------------|----------|-----|----------------|--|--|--|--|
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 18B | 0.289 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 18B | 0.000454 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 19A | 0.216 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 19A | 0.000251 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 19B | 0.220 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 19B | 0.000271 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 20A | 0.319 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 20A | 0.00196 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 20B | 0.233 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 20B | 0.000870 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 21A | 0.263 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 21A | 0.000830 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 21B | 0.190 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 21B | 0.00154 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 22A | 0.260 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 22A | 0.000985 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 22B | 0.242 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 22B | 0.00381 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 23A | 0.122 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 23A | 0.000259 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 23B | 0.117 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 23B | 0.000225 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 24A | 0.115 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 24A | 0.000258 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 24B | 0.113 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 24B | 0.000250 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 25A | 0.456 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 25A | 0.000305 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 25B | 0.539 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 25B | 0.000516 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 26A | 0.101 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 26A | 0.000151 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 26B | 0.0720 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 26B | 0.000125 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 27A | 0.0873 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 27A | 0.000101 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 27B | 0.0628 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 27B | 0.000082 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 28A | 0.216 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 28A | 0.00318 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 28B | 0.103 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 28B | 0.00364 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 29A | 0.696 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 29A | 0.00626 | x | Shut off water | Check for galvanized nipples, flush, and re-test | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 29B | 0.286 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 29B | 0.00476 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 30A | 0.417 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 30A | 0.000726 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 30B | 0.406 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 30B | 0.000494 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 31A | 0.0408 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 31A | 0.000484 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 31B | 0.0278 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 31B | 0.000311 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 32A | 0.0884 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 32A | 0.000191 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 32B | 0.0815 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 32B | 0.000192 | N/A | | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 33A | 0.0751 | N/A | | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 33A | 0.000188 | N/A | | | | | |

| | | | | | | | |
|-------------------|---|----------|--|--|--|--|--|
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 33B | 0.0644 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 33B | 0.000325 | N/A | | | | |
| Copper (Cu)-Total | ST. JAMES COLLEGIATE - 410 - 34A SOURCE | 0.823 | N/A | | | | |
| Lead (Pb)-Total | ST. JAMES COLLEGIATE - 410 - 34A SOURCE | 0.0291 | No action required, Not for drinking water | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 1A SOURCE | 0.138 | No action required, Not for drinking water | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 1A SOURCE | 0.0180 | No action required, Not for drinking water | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 2A | 0.134 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 2A | 0.00106 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 2B | 0.173 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 2B | 0.000392 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 3A | 0.207 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 3A | 0.00393 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 3B | 0.195 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 3B | 0.00412 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 4A | 0.218 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 4A | 0.0630 | x Shut off water | Check for galvanized nipples, flush, and re-test | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 4B | 0.0739 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 4B | 0.00234 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 5A | 0.210 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 5A | 0.00114 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 5B | 0.500 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 5B | 0.000478 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 6A | 0.208 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 6A | 0.000327 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 6B | 0.190 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 6B | 0.000258 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 7A | 0.114 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 7A | 0.000333 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 7B | 0.124 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 7B | 0.000481 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 8A | 0.101 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 8A | 0.000483 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 8B | 0.0805 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 8B | 0.000326 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 9A | 0.0564 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 9A | 0.000252 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 9B | 0.0396 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 9B | 0.000133 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 10A | 0.0427 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 10A | 0.000129 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 10B | 0.0323 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 10B | 0.000153 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 11A | 0.187 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 11A | 0.00110 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 11B | 0.171 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 11B | 0.000331 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 12A | 0.109 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 12A | 0.000878 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 12B | 0.107 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 12B | 0.000711 | N/A | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 13A | 0.130 | N/A | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 13A | 0.000798 | N/A | | | | |

| | | | | | | | | | |
|-------------------|---|-----------|-----|--|--|--|--|--|--|
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 13B | 0.133 | N/A | | | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 13B | 0.000699 | N/A | | | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 14A | 0.0731 | N/A | | | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 14A | 0.000201 | N/A | | | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 14B | 0.0686 | N/A | | | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 14B | 0.000155 | N/A | | | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 15A | 0.0664 | N/A | | | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 15A | 0.000173 | N/A | | | | | | |
| Copper (Cu)-Total | HERITAGE SCHOOL - 160 - 15B | 0.0677 | N/A | | | | | | |
| Lead (Pb)-Total | HERITAGE SCHOOL - 160 - 15B | 0.000187 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 1A | 0.263 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 1A | 0.000468 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 1B | 0.296 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 1B | 0.000484 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 2A | 0.196 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 2A | 0.000352 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 2B | 0.224 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 2B | 0.000283 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 3A | 0.231 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 3A | 0.000294 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 3B | 0.238 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 3B | 0.000104 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 4A | 0.252 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 4A | 0.000697 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 4B | 0.272 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 4B | 0.00141 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 5A | 0.207 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 5A | 0.000799 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 5B | 0.298 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 5B | 0.00144 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 6A | 0.138 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 6A | 0.000165 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 6B | 0.160 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 6B | 0.000153 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 7A | 0.336 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 7A | 0.000168 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 7B | 0.312 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 7B | 0.000175 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 8A | 0.245 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 8A | 0.000131 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 8B | 0.257 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 8B | 0.000152 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 9A | 0.260 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 9A | 0.000117 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 9B | 0.265 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 9B | 0.000101 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 10A | 0.0395 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 10A | 0.000064 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 10B | 0.0435 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 10B | 0.000051 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 11A | 0.102 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 11A | 0.000077 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 11B | 0.0839 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 11B | 0.000092 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 12A | 0.253 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 12A | 0.000277 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 12B | 0.281 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 12B | 0.000181 | N/A | | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 13A | 0.00163 | N/A | | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 13A | <0.000050 | N/A | | | | | | |

| | | | | | | | | |
|-------------------|---|-----------|------------------|--|--|--|--|--|
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 13B | 0.00150 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 13B | <0.000050 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 14A | 0.155 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 14A | 0.000608 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 14B | 0.141 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 14B | 0.000508 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 15A | 0.179 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 15A | 0.000528 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 15B | 0.112 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 15B | 0.000189 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 16A | 0.114 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 16A | 0.000782 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 16B | 0.122 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 16B | 0.00104 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 17A | 0.198 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 17A | 0.00232 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 17B | 0.193 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 17B | 0.00160 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 18A | 0.354 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 18A | 0.000749 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 18B | 0.323 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 18B | 0.00220 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 19A | 0.146 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 19A | 0.000203 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 19B | 0.124 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 19B | 0.000112 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 20A | 0.207 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 20A | 0.000354 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 20B | 0.193 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 20B | 0.00355 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 21A | 0.234 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 21A | 0.000612 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 21B | 0.232 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 21B | 0.000594 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 22A | 0.231 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 22A | 0.000574 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 22B | 0.233 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 22B | 0.000640 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 23A | 0.341 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 23A | 0.00149 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 23B | 0.356 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 23B | 0.00189 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 24A | 0.372 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 24A | 0.00268 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 24B | 0.266 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 24B | 0.00145 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 25A | 0.0213 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 25A | 0.000077 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 25B | 0.0201 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 25B | 0.000079 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 26A | 0.0203 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 26A | 0.000182 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 26B | 0.0192 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 26B | 0.000145 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 27A | 0.379 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 27A | 0.00809 | x Shut off water | Check for galvanized nipples, flush, and re-test | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 27B | 0.335 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 27B | 0.00431 | N/A | | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 28A | 0.231 | N/A | | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 28A | 0.000931 | N/A | | | | | |

| | | | | | | | |
|-------------------|--|----------|--|--|--|--|--|
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 28B | 0.228 | N/A | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 28B | 0.000851 | N/A | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 29A | 0.186 | N/A | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 29A | 0.000489 | N/A | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 29B | 0.166 | N/A | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 29B | 0.000416 | N/A | | | | |
| Copper (Cu)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 30A SOURCE | 1.10 | N/A | | | | |
| Lead (Pb)-Total | COLLEGE STUREON HEIGHT COLLEGIATE - 430 - 30A SOURCE | 0.856 | No action required, Not for drinking water | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 1A | 0.202 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 1A | 0.000071 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 1B | 0.236 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 1B | 0.000070 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 2A | 0.0643 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 2A | 0.00217 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 3A | 0.162 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 3A | 0.000241 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 3B | 0.176 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 3B | 0.000306 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 4A | 0.188 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 4A | 0.000100 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 4B | 0.236 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 4B | 0.000141 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 5A | 0.186 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 5A | 0.000134 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 5B | 0.168 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 5B | 0.000123 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 6A | 0.222 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 6A | 0.000096 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 6B | 0.189 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 6B | 0.000060 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 7A | 0.199 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 7A | 0.000321 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 7B | 0.174 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 7B | 0.000138 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 8A | 0.251 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 8A | 0.000185 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 8B | 0.273 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 8B | 0.000117 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 9A | 0.134 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 9A | 0.000714 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 9B | 0.0759 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 9B | 0.000402 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 10A | 0.155 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 10A | 0.000181 | N/A | | | | |
| Copper (Cu)-Total | BRITANNIA - 725 - 10B | 0.200 | N/A | | | | |
| Lead (Pb)-Total | BRITANNIA - 725 - 10B | 0.000187 | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 1A | 0.199 | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 1A | 0.00147 | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 1B | 0.182 | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 1B | 0.000955 | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 2A | 0.180 | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 2A | 0.00126 | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 2B | 0.187 | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 2B | 0.00115 | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 3A | 0.289 | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 3A | 0.00100 | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 3B | 0.416 | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 3B | 0.00159 | N/A | | | | |

| | | | | | | | | |
|-------------------|------------------------------------|----------|---|---------------------|---|--|--|--|
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 4A | 0.255 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 4A | 0.00330 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 4B | 0.252 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 4B | 0.000944 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 5A | 0.167 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 5A | 0.000715 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 5B | 0.119 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 5B | 0.000437 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 6A | 0.407 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 6A | 0.00249 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 6B | 0.413 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 6B | 0.00273 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 7A | 0.498 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 7A | 0.00700 | x | Shut off water | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 7B | 0.561 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 7B | 0.00373 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 8A | 0.282 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 8A | 0.00323 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 8B | 0.527 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 8B | 0.00836 | x | "Do not drink" sign | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 9A | 0.178 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 9A | 0.000661 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 9B | 0.122 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 9B | 0.000236 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 10A | 0.235 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 10A | 0.00588 | x | "Do not drink" sign | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 10B | 0.331 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 10B | 0.00895 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 11A | 0.184 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 11A | 0.00123 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 11B | 0.130 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 11B | 0.000781 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 12A | 0.0852 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 12A | 0.000429 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 12B | 0.0801 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 12B | 0.000411 | | N/A | | | | |
| Copper (Cu)-Total | BANNATYNE SHOOL - 120 - 13A SOURCE | 1.37 | | N/A | | | | |
| Lead (Pb)-Total | BANNATYNE SHOOL - 120 - 13A SOURCE | 0.195 | | N/A | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 1A SOURCE | 0.945 | | N/A | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 1A SOURCE | 0.00203 | | N/A | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 2A | 0.0792 | | N/A | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 2A | 0.000121 | | N/A | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 2B | 0.0794 | | N/A | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 2B | 0.000265 | | N/A | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 3A | 0.306 | | N/A | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 3A | 0.00835 | x | "Do not drink" sign | Change aerator, flush, re-test to see if below new guideline. | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 3B | 0.409 | | N/A | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 3B | 0.00483 | | N/A | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 4A | 0.0632 | | N/A | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 4A | 0.000072 | | N/A | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 4B | 0.0811 | | N/A | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 4B | 0.000074 | | N/A | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 5A | 0.0659 | | N/A | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 5A | 0.000074 | | N/A | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 5B | 0.0764 | | N/A | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 5B | 0.000075 | | N/A | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 6A | 0.210 | | N/A | | | | |

| | | | | | | | | |
|-------------------|------------------------------|-----------|-----|--|--|--|--|--|
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 6A | 0.000333 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 6B | 0.200 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 6B | 0.000282 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 7A | 0.280 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 7A | 0.000217 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 7B | 0.244 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 7B | 0.000091 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 8A | 0.0902 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 8A | <0.000050 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 8B | 0.0749 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 8B | <0.000050 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 9A | 0.143 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 9A | 0.000123 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 9B | 0.0951 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 9B | 0.000082 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 10A | 0.307 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 10A | 0.000124 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 10B | 0.310 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 10B | 0.000116 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 11A | 0.348 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 11A | 0.000094 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 11B | 0.355 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 11B | 0.000086 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 12A | 0.294 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 12A | 0.000527 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 12B | 0.289 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 12B | 0.000241 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 13A | 0.325 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 13A | 0.000999 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 13B | 0.326 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 13B | 0.000270 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 14A | 0.378 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 14A | 0.000060 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 14B | 0.394 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 14B | <0.000050 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 15A | 0.389 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 15A | <0.000050 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 15B | 0.393 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 15B | <0.000050 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 16A | 0.380 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 16A | 0.000511 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 16B | 0.518 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 16B | 0.000767 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 17A | 0.154 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 17A | 0.000266 | N/A | | | | | |
| Copper (Cu)-Total | CRESTVIEW SCHOOL - 155 - 17B | 0.126 | N/A | | | | | |
| Lead (Pb)-Total | CRESTVIEW SCHOOL - 155 - 17B | 0.000096 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 1A | 0.0830 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 1A | 0.000250 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 1B | 0.0624 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 1B | 0.000125 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 2A | 0.150 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 2A | 0.000377 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 2B | 0.137 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 2B | 0.000271 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 3A | 0.138 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 3A | 0.000305 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 3B | 0.116 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 3B | 0.000212 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 4A | 0.266 | N/A | | | | | |

| | | | | | | | | |
|-------------------|------------------------------------|----------|-----|--|--|--|--|--|
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 4A | 0.00106 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 4B | 0.268 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 4B | 0.000924 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 5A | 0.154 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 5A | 0.000581 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 5B | 0.156 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 5B | 0.000451 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 6A | 0.134 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 6A | 0.000355 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 6B | 0.119 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 6B | 0.000286 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 7A | 0.108 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 7A | 0.000317 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 7B | 0.109 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 7B | 0.000236 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 8A | 0.0567 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 8A | 0.000167 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 8B | 0.0613 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 8B | 0.000174 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 9A | 0.0616 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 9A | 0.000226 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 9B | 0.0597 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 9B | 0.000242 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 10A | 0.106 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 10A | 0.000371 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 10B | 0.121 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 10B | 0.000274 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 11A | 0.386 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 11A | 0.00312 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 11B | 0.396 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 11B | 0.00186 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 12A SOURCE | 0.0571 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 12A SOURCE | 0.000181 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 13A | 0.137 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 13A | 0.000251 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 13B | 0.136 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 13B | 0.000274 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 14A | 0.140 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 14A | 0.000284 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 14B | 0.128 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 14B | 0.000248 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 15A | 0.132 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 15A | 0.000313 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 15B | 0.128 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 15B | 0.000318 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 16A | 0.266 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 16A | 0.00200 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 16B | 0.216 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 16B | 0.00147 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 17A | 0.147 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 17A | 0.00207 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 17B | 0.174 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 17B | 0.00153 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 18A | 0.164 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 18A | 0.00147 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 18B | 0.142 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 18B | 0.000542 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 19A | 0.177 | N/A | | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 19A | 0.00194 | N/A | | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 19B | 0.138 | N/A | | | | | |

| | | | | | | | |
|-------------------|---------------------------------------|----------|--|--|--|--|--|
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 19B | 0.000537 | N/A | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 20A | 0.0993 | N/A | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 20A | 0.000178 | N/A | | | | |
| Copper (Cu)-Total | VOYAGEUR SCHOOL - 210 - 20B | 0.0898 | N/A | | | | |
| Lead (Pb)-Total | VOYAGEUR SCHOOL - 210 - 20B | 0.000164 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 1A | 0.262 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 1A | 0.00172 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 1B | 0.244 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 1B | 0.00198 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 2A | 0.196 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 2A | 0.000973 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 2B | 0.142 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 2B | 0.000798 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 3A | 0.119 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 3A | 0.000397 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 3B | 0.102 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 3B | 0.000265 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 4A | 0.613 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 4A | 0.00196 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 4B | 0.600 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 4B | 0.00199 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 5A | 0.620 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 5A | 0.00185 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 5B | 0.591 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 5B | 0.00146 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 6A | 0.640 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 6A | 0.00401 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 6B | 0.650 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 6B | 0.00384 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 7A | 0.523 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 7A | 0.000841 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 7B | 0.511 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 7B | 0.000906 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 8A | 0.168 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 8A | 0.000410 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 8B | 0.162 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 8B | 0.000375 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 9A SOURCE | 0.300 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 9A SOURCE | 0.0693 | No action required, Not for drinking water | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 10A | 0.245 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 10A | 0.00158 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 10B | 0.194 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 10B | 0.000833 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 11A | 0.215 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 11A | 0.000627 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 11B | 0.207 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 11B | 0.000703 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 12A | 0.357 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 12A | 0.00112 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 12B | 0.481 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 12B | 0.000457 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 13A | 0.486 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 13A | 0.00274 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 13B | 0.517 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 13B | 0.000943 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 14A | 0.329 | N/A | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 14A | 0.000948 | N/A | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 14B | 0.341 | N/A | | | | |

| | | | | | | | | |
|-------------------|---|----------|-----|--|--|--|--|--|
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 14B | 0.000875 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 15A | 0.252 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 15A | 0.00108 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 15B | 0.336 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 15B | 0.00121 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 16A | 0.329 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 16A | 0.00123 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 16B | 0.364 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 16B | 0.000908 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 17A | 0.157 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 17A | 0.00155 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 17B | 0.221 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 17B | 0.00283 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 18A | 0.165 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 18A | 0.000303 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 18B | 0.169 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 18B | 0.000309 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 19A | 0.351 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 19A | 0.000719 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 19B | 0.357 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 19B | 0.000507 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 20A | 0.362 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 20A | 0.00147 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 20B | 0.349 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 20B | 0.00132 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 21A | 0.333 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 21A | 0.00130 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 21B | 0.336 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 21B | 0.000938 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 22A | 0.171 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 22A | 0.00105 | N/A | | | | | |
| Copper (Cu)-Total | WESTWOOD COLLEGIATE - 425 - 22B | 0.246 | N/A | | | | | |
| Lead (Pb)-Total | WESTWOOD COLLEGIATE - 425 - 22B | 0.00242 | N/A | | | | | |
| Copper (Cu)-Total | Board Office 750-1A - STAFF ROOM SOURCE | 0.108 | N/A | | | | | |
| Lead (Pb)-Total | Board Office 750-1A - STAFF ROOM SOURCE | 0.000242 | N/A | | | | | |
| Copper (Cu)-Total | Board Office 750-1A - STAFF ROOM SOURCE | 0.108 | N/A | | | | | |
| Lead (Pb)-Total | Board Office 750-1A - STAFF ROOM SOURCE | 0.000242 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 1A | 0.205 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 1A | 0.000532 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 1B | 0.178 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 1B | 0.000415 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 2A | 0.183 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 2A | 0.000534 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 2B | 0.170 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 2B | 0.000466 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 3A | 0.178 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 3A | 0.000748 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 3B | 0.155 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 3B | 0.000741 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 4A | 0.135 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 4A | 0.000602 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 4B | 0.124 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 4B | 0.000822 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 5A | 0.339 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 5A | 0.000124 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 5B | 0.345 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 5B | 0.000115 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 6A | 0.321 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 6A | 0.000112 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 6B | 0.343 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 6B | 0.000119 | N/A | | | | | |

| | | | | | | | | |
|-------------------|---|----------|-----|----------------|--|--|--|--|
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 7A | 0.302 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 7A | 0.00119 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 7B | 0.318 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 7B | 0.00273 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 8A | 0.111 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 8A | 0.000110 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 8B | 0.0739 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 8B | 0.000073 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 9A | 0.0628 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 9A | 0.000212 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 9B | 0.0600 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 9B | 0.000121 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 10A | 0.303 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 10A | 0.00110 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 10B | 0.397 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 10B | 0.00164 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 11A | 0.345 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 11A | 0.00218 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 11B | 0.308 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 11B | 0.00115 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 12A SOURCE | 1.38 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 12A SOURCE | 0.00388 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 13A | 0.114 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 13A | 0.000357 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 13B | 0.104 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 13B | 0.00117 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 14A | 0.0770 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 14A (Slop Sink...not for drinking) | 0.0140 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 15A | 0.0903 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 15A | 0.000083 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 15B | 0.107 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 15B | 0.000159 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 16A | 0.100 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 16A | 0.000189 | N/A | | | | | |
| Copper (Cu)-Total | LINWOOD SCHOOL - 180 - 16B | 0.122 | N/A | | | | | |
| Lead (Pb)-Total | LINWOOD SCHOOL - 180 - 16B | 0.000158 | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 1A SOURCE | 0.236 | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 1A SOURCE | 0.000680 | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 2A | 0.388 | x | Shut off water | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 2A | 0.00572 | x | Shut off water | Check for galvanized nipples, flush, and re-test | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 2B | 0.372 | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 2B | 0.00276 | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 3A | 0.281 | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 3A | 0.00189 | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 3B | 0.268 | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 3B | 0.00198 | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 4A | 0.211 | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 4A | 0.00241 | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 4B | 0.270 | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 4B | 0.00525 | x | Shut off water | Check for galvanized nipples, flush, and re-test | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 5A | 0.215 | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 5A | 0.00253 | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 5B | 0.274 | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 5B | 0.00176 | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 6A | 0.346 | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 6A | 0.000854 | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 6B | 0.360 | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 6B | 0.000454 | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 7A | 0.325 | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 7A | 0.00125 | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 7B | 0.291 | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 7B | 0.000643 | N/A | | | | | |

| | | | | | | | | | |
|-------------------|---|-----------|---|--|--|--|--|--|--|
| Copper (Cu)-Total | JAMESWOOD 165 - 8A SOURCE | 0.759 | | No action required, Not for drinking water | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 8A SOURCE | 0.122 | | No action required, Not for drinking water | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 9A | 0.192 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 9A | 0.000571 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 9B | 0.172 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 9B | 0.000391 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 10A | 0.400 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 10A | 0.00120 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 10B | 0.416 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 10B | 0.00137 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 11A | 0.297 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 11A | 0.00232 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 11B | 0.342 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 11B | 0.00226 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 12A | 0.315 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 12A | 0.00228 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 12B | 0.283 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 12B | 0.00208 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 13A | 0.387 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 13A | 0.00101 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 13B | 0.493 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 13B | 0.000247 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 14A | 0.304 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 14A | 0.00308 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 14B | 0.196 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 14B | 0.00184 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 15A | 0.462 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 15A | 0.00287 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 165 - 15B | 0.514 | | N/A | | | | | |
| Lead (Pb)-Total | JAMESWOOD 165 - 15B | 0.00267 | | N/A | | | | | |
| Copper (Cu)-Total | JAMESWOOD 760 - 1A - SOURCE | 0.132 | | No action required, Not for drinking water | | | | | |
| Lead (Pb)-Total | JAMESWOOD 760 - 1A - SOURCE | 0.00172 | | No action required, Not for drinking water | | | | | |
| Copper (Cu)-Total | MAINTENANCE SHOP 760 - 2A - REFRIDGERATOR | 0.00252 | | N/A | | | | | |
| Lead (Pb)-Total | MAINTENANCE SHOP 760 - 2A - REFRIDGERATOR | <0.000050 | | N/A | | | | | |
| Copper (Cu)-Total | MAINTENANCE SHOP 760 - 2B - REFRIDGERATOR | 0.00226 | | N/A | | | | | |
| Lead (Pb)-Total | MAINTENANCE SHOP 760 - 2B - REFRIDGERATOR | <0.000050 | | N/A | | | | | |
| Copper (Cu)-Total | MAINTENANCE SHOP 760 - 3A - FAUCET | 0.129 | | N/A | | | | | |
| Lead (Pb)-Total | MAINTENANCE SHOP 760 - 3A - FAUCET | 0.000535 | | N/A | | | | | |
| Copper (Cu)-Total | MAINTENANCE SHOP 760 - 3B - FAUCET | 0.132 | | N/A | | | | | |
| Lead (Pb)-Total | MAINTENANCE SHOP 760 - 3B - FAUCET | 0.000504 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 1A SOURCE | 0.362 | x | No action required, Not for drinking water | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 1A SOURCE | 0.0708 | x | No action required, Not for drinking water | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 2A | 0.344 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 2A | 0.00123 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 2B | 0.344 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 2B | 0.00154 | | N/A | | | | | |

| | | | | | | | | | |
|-------------------|-----------------------|----------|---|----------------|--|--|--|--|--|
| Copper (Cu)-Total | JOHN TAYLOR 405 - 3A | 0.194 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 3A | 0.00269 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 3B | 0.190 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 3B | 0.00100 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 4A | 0.292 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 4A | 0.00293 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 4B | 0.308 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 4B | 0.00245 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 5A | 0.0945 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 5A | 0.000923 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 5B | 0.0521 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 5B | 0.000370 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 6A | 0.0516 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 6A | 0.000109 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 6B | 0.0523 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 6B | 0.000104 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 7A | 0.0556 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 7A | 0.000096 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 7B | 0.0562 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 7B | 0.000108 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 8A | 0.285 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 8A | 0.000420 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 8B | 0.280 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 8B | 0.00100 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 9A | 0.207 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 9A | 0.00116 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 9B | 0.165 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 9B | 0.00134 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 10A | 0.911 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 10A | 0.00281 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 10B | 0.795 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 10B | 0.00332 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 11A | 0.560 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 11A | 0.00292 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 11B | 1.77 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 11B | 0.00182 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 12A | 0.0404 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 12A | 0.000783 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 12B | 0.0373 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 12B | 0.000439 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 13A | 1.48 | x | Shut off water | Check for galvanized nipples, flush, and re-test | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 13A | 0.00925 | x | Shut off water | Check for galvanized nipples, flush, and re-test | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 13B | 3.04 | x | Shut off water | Check for galvanized nipples, flush, and re-test | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 13B | 0.0248 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 14A | 0.101 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 14A | 0.000136 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 14B | 0.0751 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 14B | 0.000165 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 15A | 0.0966 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 15A | 0.000214 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 15B | 0.0970 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 15B | 0.000362 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 16A | 0.146 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 16A | 0.000225 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 16B | 0.103 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 16B | 0.000154 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 17A | 0.188 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 17A | 0.000392 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 17B | 0.137 | | N/A | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 17B | 0.000251 | | N/A | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 18A | 0.136 | | N/A | | | | | |

| | | | | | | | | | |
|-------------------|-----------------------|----------|-----|--|--|--|--|--|--|
| Lead (Pb)-Total | JOHN TAYLOR 405 - 18A | 0.000224 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 18B | 0.158 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 18B | 0.000299 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 19A | 0.135 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 19A | 0.000205 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 19B | 0.0864 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 19B | 0.000325 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 20A | 0.0166 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 20A | 0.000258 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 20B | 0.0165 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 20B | 0.000301 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 21A | 0.176 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 21A | 0.000508 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 21B | 0.334 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 21B | 0.00112 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 22A | 0.309 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 22A | 0.000153 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 22B | 0.404 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 22B | 0.000148 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 23A | 0.0617 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 23A | 0.000308 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 23B | 0.0554 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 23B | 0.000227 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 24A | 0.393 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 24A | 0.00127 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 24B | 0.342 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 24B | 0.000713 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 25A | 0.518 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 25A | 0.00181 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 25B | 0.472 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 25B | 0.00128 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 26A | 0.964 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 26A | 0.00175 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 26B | 0.625 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 26B | 0.000982 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 27A | 0.423 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 27A | 0.00235 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 27B | 0.417 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 27B | 0.00153 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 28A | 0.155 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 28A | 0.000881 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 28B | 0.117 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 28B | 0.000433 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 29A | 0.357 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 29A | 0.00112 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 29B | 0.364 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 29B | 0.00135 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 30A | 0.0839 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 30A | 0.000313 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 30B | 0.0674 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 30B | 0.000206 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 31A | 0.0633 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 31A | 0.00156 | N/A | | | | | | |
| Copper (Cu)-Total | JOHN TAYLOR 405 - 31B | 0.0559 | N/A | | | | | | |
| Lead (Pb)-Total | JOHN TAYLOR 405 - 31B | 0.000146 | N/A | | | | | | |